

**ANDERSON CIRCLE WATER CORPORATION (PWS #4010005)
SOURCE WATER ASSESSMENT FINAL REPORT**

March 6, 2002



**State of Idaho
Department of Environmental Quality**

Disclaimer: This publication has been developed as part of an informational service for the source water assessments of public water systems in Idaho and is based on data available at the time and the professional judgement of the staff. Although reasonable efforts have been made to present accurate information, no guarantees, including expressed or implied warranties of any kind, are made with respect to this publication by the State of Idaho or any of its agencies, employees, or agents, who also assume no legal responsibility for the accuracy of presentations, comments, or other information in this publication. The assessment is subject to modification if new data is produced.

Executive Summary

Under the federal Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency (EPA) to assess every source of public drinking water for its relative sensitivity to contaminants regulated by the act. The assessment for your particular system is based on a land use inventory of the designated source water area, sensitivity factors associated with each well, and characteristics of the aquifer that supplies your community with drinking water.

This report, *Source Water Assessment for the Anderson Circle Water Corporation, located in Boise, Idaho*, describes the public drinking water system, the boundaries of the zones of water contribution, and the associated potential contaminant sources located within those boundaries. This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. **The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The Anderson Circle Water Corporation (PWS #4010005) drinking water system consists of a single well. Well #1 rated an overall high susceptibility to inorganic (IOC), volatile organic (VOC), synthetic organic (SOC), and microbial contaminants. These ratings can be attributed, in large part, to the presence of a potential contaminant source within a 50-foot radius of the well bore. This potential source is a seasonal irrigation ditch, which is situated approximately 30 feet from the Anderson Circle well. Because it is unknown whether the ditch is hydraulically connected to the well water, the overall susceptibility scores were increased. Without any potential sources of contamination in this 50-foot radius circle, the well would have rated a moderate overall susceptibility to all classes of pollutants.

The predominant land use within the designated drinking water capture zone is urban/commercial. These areas may be vulnerable to ground water contamination due to urban runoff during storm events, improper disposal of household hazardous wastes, and industrial pollutants, to name just a few.

Nevertheless, there have been no serious water chemistry problems in the history of this system, although total coliform bacteria were discovered in the distribution system in January of 1992 and again in January of 1995. Nitrate levels have averaged 3.6 milligrams per liter (mg/L) since 1993, never seriously jeopardizing the maximum contaminant level (MCL) for nitrate, which is 10.0 mg/L. The well has never tested positive for SOC's or VOC's during any water chemistry tests. The Anderson Circle Water Corporation water system is over 50 years old, but appears to be well maintained.

Although contaminant levels in the drinking water system have never exceeded current MCLs for any of the pollutants regulated under the Safe Drinking Water Act, the Anderson Circle Water Corporation should be aware that the possibility of contamination still exists. There are numerous potential sources of contamination within the delineated drinking water capture zone. These sources can be found in Table 1 (pages 20-21), along with the class of contaminants stored at each site. In Addition, the 1995 Ground Water Under Direct Influence (GWUDI) field survey conducted by the Central District Health Department indicates the presence of a sewer line, which is situated about 50 feet from the well bore. For the purposes of the susceptibility analysis, this sewer line was considered a possible source of IOC and microbial pollution.

Furthermore, Federal Way and Broadway Avenue pass directly through the designated source water area. Because both of these roads serve as important transportation thoroughfares for the region, they were incorporated into the analysis as possible origins for all classes of pollutants.

A known VOC plume also intercepts the edge drinking water capture zone. The Anderson Circle Water Corporation may want to periodically monitor for VOCs, since they are known to be in the ground water immediately up-gradient from the well.

This assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

For the Anderson Circle Water Corporation, drinking water protection activities should first focus on continued maintenance of the sanitary seal and distribution system. Actions should also be taken to keep a 50-foot radius circle clear around the wellhead. Because the aforementioned irrigation ditch passes through this zone, the system may want to investigate practices that could minimize its impact on the drinking water supply. If the system should need to expand in the future, new well sites should be located in areas with as few potential sources of contamination as possible, and the site should be reserved and protected for this specific use. Any spills occurring on either Federal Way or Broadway Avenue should be monitored and dealt with expeditiously.

Because a portion of the ground water capture zone is outside the direct jurisdiction of the Anderson Circle Water Corporation, the creation of partnerships with state and local agencies and industry groups are critical to the success of drinking water protection. The water system may want to cooperate with the businesses in Table 1 (pages 20-21) to encourage the use of pollution prevention methods and specific best management practices (BMPs). Should microbial contamination become a continuing problem, appropriate disinfection practices would need to be implemented to ensure the health of the Anderson Circle Water Corporation residents.

Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term. A strong public education program should be a primary focus of any drinking water protection plan, especially since the delineation contains some urban and residential land uses. Public education topics could include proper lawn care practices, household hazardous waste disposal methods, and the importance of water conservation to name but a few.

There are multiple resources available to help communities implement protection programs, including the Drinking Water Academy of the U.S. Environmental Protection Agency. In addition, because two major transportation corridors (Federal Way and Broadway Avenue) pass through the delineation, the Idaho Department of Transportation should be involved in any protection measures. Drinking water protection practices dealing with agriculture should be coordinated with the Idaho State Department of Agriculture, the Soil Conservation Commission, the Ada County Soil Conservation District, and the Natural Resources Conservation Service.

A community must incorporate a variety of strategies in order to develop a comprehensive drinking

water protection plan, be they regulatory in nature (i.e. zoning, permitting) or non-regulatory in nature (i.e. good housekeeping, public education, specific best management practices). For assistance in developing protection strategies please contact the Boise Regional Office of the Idaho Department of Environmental Quality or the Idaho Rural Water Association.

SOURCE WATER ASSESSMENT FOR THE ANDERSON CIRCLE WATER CORPORATION, BOISE, IDAHO

Section 1. Introduction - Basis for Assessment

The following sections contain information necessary to understand how and why this assessment was conducted. **It is important to review this information to understand what the ranking of this assessment means.** A map showing the delineated source water assessment area and the inventory of significant potential sources of contamination identified within that area are contained in this report (Attachment A, pages 17-21). The list of significant potential contaminant source categories and their rankings used to develop the assessment is also attached.

Level of Accuracy and Purpose of the Assessment

The Idaho Department of Environmental Quality (DEQ) is required by the U.S. Environmental Protection Agency (EPA) to assess each drinking water source in Idaho for their relative susceptibility to contaminants regulated by the Safe Drinking Water Act Amendments of 1996. This assessment is based on a land use inventory of the delineated source water area, sensitivity factors associated with each well, and aquifer characteristics. Since there are over 2,900 public water sources in Idaho, there is limited time and resources available to accomplish the assessments. All of these assessments must be completed by May of 2003. An in-depth, site-specific investigation of each significant potential source of contamination is not possible. **Therefore, this assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The ultimate goal of the assessment is to provide data to local communities to develop a protection strategy for their drinking water supply system. DEQ recognizes that pollution prevention activities generally require less time and money to implement than treatment of a public water supply system once it has been contaminated. DEQ encourages communities to balance resource protection with economic growth and development. The decision as to the amount and types of information necessary to develop a drinking water protection program should be determined by the local community based on its own needs and limitations. Drinking water protection is one facet of a comprehensive growth plan, and it can complement ongoing local planning efforts.

Section 2. Conducting the Assessment

General Description of the Source Water Quality

The Anderson Circle Water Corporation has a community public drinking water system serving approximately 50 people that is located in Ada County near the intersection of Salem St. and Ralfroy St. in Boise, Idaho (Figure 1, page 18). Residents receive their water from a single well.

There have been no serious water chemistry problems in the history of this system, although total coliform bacteria were discovered in the distribution system in January of 1992 and again in January of 1995. Nitrate levels have averaged 3.6 mg/L since 1993, never seriously jeopardizing the MCL for nitrate, which is 10.0 mg/L. The well has never tested positive for SOCs or VOCs during any water chemistry tests. The Anderson Circle Water Corporation water system is over 50 years old, but appears to be well maintained.

Defining the Zones of Contribution – Delineation

The delineation process establishes the physical area around a well that will become the focal point of the assessment. The process includes mapping the boundaries of the zone of contribution into time-of-travel (TOT) zones (regions indicating the number of years necessary for a particle of water to reach a pumping well) for water in the aquifer. DEQ contracted with BARR Engineering to perform the delineations using a combination of MODFLOW and a refined analytical element computer model approved by the EPA in determining the 3-year (Zone 1B), 6-year (Zone 2), and 10-year (Zone 3) TOT for water associated with the Boise Valley aquifer. The computer model used site specific data, assimilated by BARR Engineering from a variety of sources including area well logs, the Treasure Valley Hydrologic Project, and hydrogeologic reports (detailed below in Section 3).

Identifying Potential Sources of Contamination

A potential source of contamination is defined as any facility or activity that stores, uses, or produces, as a product or by-product, the contaminants regulated under the Safe Drinking Water Act and has a sufficient likelihood of releasing such contaminants at levels that could pose a concern relative to drinking water sources. The goal of the inventory process is to locate and describe those facilities, land uses, and environmental conditions that are potential sources of ground water contamination. The locations of potential sources of contamination within the delineation areas were obtained by field surveys conducted by DEQ and from available databases.

It is important to understand that a release may never occur from a potential source of contamination provided best management practices are used at the facility. Many potential sources of contamination are regulated at the federal level, state level, or both to reduce the risk of release. Therefore, when a business, facility, or property is identified as a potential contaminant source, this should not be interpreted to mean that this business, facility, or property is in violation of any local, state, or federal environmental law or regulation. What it does mean is that the potential for contamination exists due to the nature of the business, industry, or operation. There are a number of methods that water systems can use to work cooperatively with these possible contamination sources, including educational visits and inspections of stored materials. Many owners of such facilities may not even be aware that they are located near a public water supply well.

Contaminant Source Inventory Process

A two-phased contaminant inventory of the study area was conducted in October and November of 2001. The first phase involved identifying and documenting potential contaminant sources within Anderson Circle Water Corporation source water assessment area (Figure 2, page 19) through the use of computer databases and Geographic Information System maps developed by DEQ. The second, or enhanced, phase of the contaminant inventory involved contacting the system representative, Don

Tucker, to validate the sources identified in phase one and to add any additional potential sources in the area. The delineated source water area contains numerous potential sources of contamination. These sources are listed, along with the class of contaminants stored at each site, in Table 1 (pages 20-21).

Section 3. Hydrologic Conditions of the Treasure Valley

Treasure Valley Hydrologic Project Information (Petrich and Urban, 1996; Neely and Crockett, 1998; Petrich et al., 1999)

The “Treasure Valley” is a geopolitical region that includes the lower Boise River sub-basin. The lower Boise River sub-basin begins where the Boise River exits the mountains near the Lucky Peak Reservoir. From Lucky Peak Dam the lower Boise River flows about 64 (river) miles northwestward through the Treasure Valley to its confluence with the Snake River. The Treasure Valley Hydrologic Project area encompasses the lower Boise River area, and extends south to the Snake River. The southern area is included in the study area because of ground water flow from the Lower Boise River basin south toward the Snake River.

Significant amounts of desert area were converted to flood irrigated agriculture beginning in the 1860s. Irrigation led to increases in shallow ground water levels in some regions. These shallow ground water levels provided an inexpensive and readily obtainable source of water supply that is used extensively throughout the valley. Much of the population growth in the Treasure Valley has been occurring in previously flood-irrigated agricultural areas, resulting in increased pumpage and a reduction in local aquifer recharge. In addition, irrigation in some areas has become more efficient, reducing the amount of irrigation-related infiltration. Decreasing aquifer recharge and increasing pumpage is thought to be contributing to the decline of ground water levels in some areas.

The Treasure Valley experiences a temperate and arid-to-semiarid climate. Average high temperatures range from about 90°F in summer to 36°F in winter; low temperatures range from about 20°F in winter to about 56°F in summer. The average precipitation ranges from about 8 to 14 inches throughout most of the valley, most of which falls during the colder months in the form of snow in higher elevations and rain in the low-lying valleys.

Major surface water bodies include the Boise River, Lake Lowell, and Lucky Peak Reservoir. The primary source of surface water in the Treasure Valley is the high elevation area in the Boise River basin upstream of Lucky Peak Dam. Much of the spring runoff from the snow pack in high elevation areas is stored in three reservoirs: Anderson Ranch Reservoir, Arrowrock Reservoir, and Lucky Peak Reservoir.

Regional cropland is irrigated primarily with surface water through an extensive network of reservoirs and canals. The first canals were constructed in the 1860's; there are now over 1,100 miles of major and intermediate canals in the Treasure Valley, the majority of which are owned and maintained by canal companies and irrigation districts. Primary sources of irrigation water in the Treasure Valley include the Boise, Snake, and Payette Rivers.

Hydrogeology (from Petrich et al., 1999)

The lower Boise River sub-basin (Treasure Valley) is located within the northwest-trending topographic depression known as the western Snake River Plain. The western Snake River Plain is a relatively flat lowland separating Cretaceous granitic mountains of west-central Idaho from the granitic/volcanic Owyhee mountains in southwestern Idaho. The western Snake River Plain extends from about Twin Falls, Idaho northwestward to Vale, Oregon. The Snake River Plain is about 30 miles wide in the section containing the lower Boise River.

Historically, sediments originating from the surrounding mountains began accumulating on top of thick, basal basalts. Rifting and continued subsidence maintained the lowland topography, leading to the additional accumulation of water and sediments (Othberg, 1994). Basin infilling by sediments and basalt occurred from the late Miocene through the late Pliocene (Othberg, 1994). Incision caused by flowing water in major drainages (e.g., Snake and Boise Rivers) began in the late Pliocene or early Pleistocene, although deposition of coarse sediments continued during Quaternary glaciations (Othberg, 1994).

Several Quaternary basalt flows have been described in the western Snake River Plain, and have been assigned to the upper Snake River Group (Malde, 1991; Malde and Powers, 1962). Lava flowed across portions of the ancestral Snake River Valley (Malde, 1991) in an area that is now south of the Boise River. The Snake River then changed course, incising at its present location along the southern margin of the basalt flows. More recent eruptions (from Kuna Butte and other local sources) spilled lava into the canyon south of Melba. The Snake River has since incised this basalt (Malde, 1991).

The general stratigraphy of the western Snake River Plain consists of (from top to bottom) a thick layer of sedimentary deposits underlain by a thick series of basalt flows, which in turn are underlain by older, tuffaceous sediments and basalt (Malde, 1991; Clemens, 1993). The upper thick zone of sediments (up to approximately 6,000 feet thick) distinguishes the western Snake River Plain from the eastern Snake River Plain, in which the upper section is primarily Quaternary basalt (Wood and Anderson, 1981).

The uppermost sediments and basalt belong to the Pleistocene-age Snake River Group. The Snake River Group consists of terrace sediments, Quaternary alluvium, and Pleistocene basalt flows (Wood and Anderson, 1981). Snake River Group sediments and basalts cover much of the project area (Othberg and Stanford, 1992).

The Snake River Group overlies the Idaho Group sediments. The Idaho Group sediments can be divided into two general parts (Wood and Anderson, 1981). The lower Idaho Group contains sediments described as lake and stream deposits of buff white, brown, and gray sand, silt, clay, diatomite, numerous thin beds of vitric ash, and some basaltic tuffs. The upper part of the lower Idaho Group also contains some local, thin, basalt flows. The upper Idaho Group consists of sands, claystones, and siltstones, but differs from the lower Idaho Group in that it contains a greater percentage of coarser-grained materials. The upper Idaho Group sediments are associated with a fluvial/deltaic/lacustrine depositional environment; the lower Idaho Group sediments were deposited in more of a lacustrine/deltaic environment (Wood, 1994).

Wood (1994) identified a buried lacustrine delta within the Idaho Group sediments in the Nampa-

Caldwell area. The location of the delta in the middle of the western Snake River Plain suggests that the eastern part of the Boise River basin was delta plain and flood plain at the time of deposition, while the western part was a deep lake environment. The delta probably prograded northwestward into a lake basin 830 feet deep, based upon high resolution seismic reflection data and resistivity log interpretations. The delta-plain and front sediments were shown to be mostly fine-grained, well-sorted sand with thin layers of mud (Wood, 1994). The northwest trend of the delta indicates a sediment source to the southeast, such as where the Snake River flows today (Wood, 1994).

A substantial, laterally extensive layer of clay is found at depths of 300 to 700 feet below ground surface. The clay is important because it represents, in some areas, a significant aquitard separating shallow overlying aquifers from deeper zones. The clay, often described in well logs as having a blue or gray color, has been observed as far west as Parma, and as far east as Boise (although the clay is not found in the extreme eastern portions of the Treasure Valley). The clay varies from a few feet to a few hundred feet in thickness. Although significant layers of clay are present throughout the Idaho Group sediments, individual clay units are not necessarily continuous over large areas. Also, the top of the clay can vary in elevation by up to approximately 200 feet in some locations, such as in an area west of Lake Lowell. In general, sediments above the "blue clay" are coarser-grained than the interbedded sands, silts, and clays underlying the "blue clay."

The top of the upper Idaho Group is marked in several parts of the Treasure Valley by a widespread fluvial gravel deposit known as the Tenmile gravels. Tenmile gravels contain rounded granitic rocks and felsic porphyries originating from the Idaho Batholith to the north and northeast. The Tenmile gravels range up to 500 feet in thickness along the Tenmile Ridge south of Boise, but are less than 50 feet thick in the Nampa-Caldwell area (Wood and Anderson, 1981).

Aquifer Systems and Hydrogeologic Characteristics

Ground water for municipal, industrial, rural domestic, and irrigation uses in the Treasure Valley is drawn almost entirely from Snake River Group and Idaho Group aquifers. Many domestic wells draw water from shallow aquifers, such as those in the Snake River Group deposits. Larger production wells (for municipal and agricultural uses) draw water from the deeper Idaho Group sediments.

Aquifers contained in the Snake River and Idaho Group sediments comprise shallow and regional ground water flow systems. Shallow aquifers contained in Snake River Group sediments and basalts may belong to local flow systems. Most local flow system recharge stems from irrigation infiltration and channel (e.g., streams or canals) losses. Discharge from shallow, local flow systems often is to local drains or streams. The time from recharge to discharge in shallow flow systems (residence times) probably ranges from days to tens of years.

In contrast, regional ground water flow systems extend much deeper than local flow systems. The Treasure Valley regional flow system begins in the eastern part of the valley, as indicated by downward hydraulic gradients in the Boise Fan sediments (Squires et al., 1992). Some water also enters the regional flow system as underflow from the Boise Foothills in the northeastern part of the valley. The regional flow system is thought to discharge primarily to the Boise and Snake Rivers in the western and southwestern parts of the valley.

Aquifer material characteristics, material heterogeneity, and structural controls influence Treasure

Valley ground water flow. Coarse-grained materials (e.g., sand and gravel) in upper zones are more capable of transmitting ground water than fine-grained sediments (e.g., silt and clay). Clay and silt in the Snake River sediments can restrict vertical and/or horizontal ground water movement. Perched aquifers are created when fine-grained lenses impede downward vertical flow. A distinctive clay layer, sometimes referred to as "blue clay," is present over large portions of the valley. The clay is absent in the easternmost portions of the lower Boise River Basin, but can reach a thickness of more than 200 feet toward the central and western portions of the basin.

Sequences of interbedded sand, silt, and clay, such as the Deer Flat Surface and the upper portion of the Glens Ferry Formation of the upper Idaho Group in the Nampa-Caldwell area, are the major water-producing aquifers in a large part of Canyon County (Anderson and Wood, 1981). The coarse-grained sediments in this zone produce water in excess of 2,000 gallons per minute (gpm).

The delineated source water assessment area for the Anderson Circle Water Corporation can best be described as an eastward trending triangular corridor approximately one mile long on each side (Figure 2, page 19). The actual data used by BARR Engineering in determining the source water zones of contribution are available from DEQ upon request.

Section 4. Susceptibility Analysis

The water system's susceptibility to contamination was ranked as high, moderate, or low risk according to the following considerations: hydrologic characteristics, physical integrity of the well, land use characteristics, and potentially significant contaminant sources. The susceptibility rankings are specific to a particular potential contaminant or category of contaminants. Therefore, a high susceptibility rating relative to one potential contaminant does not mean that the water system is at the same risk for all other potential contaminants. The relative ranking that is derived for each well is a qualitative, screening-level step that, in many cases, uses generalized assumptions and best professional judgement. Attachment B (pages 22-23) contains the susceptibility analysis worksheets. The following summaries describe the rationale for the susceptibility ranking.

Hydrologic Sensitivity

The hydrologic sensitivity of a well is dependent upon four factors: 1) the surface soil composition, 2) the material in the vadose zone (region between the land surface and the water table), 3) the depth to first ground water, and 4) the presence of a 50-foot thick impermeable zone above the production interval of the well. Slowly draining fine-grained soils such as silt and clay typically are more protective of ground water than coarse-grained soils such as sand and gravel. For Anderson Circle Water Corporation, regional soil information indicates the presence of poor to moderately draining soils. These soils may provide some additional protection to the source water by impeding the downward progress of contaminants in the unlikely event of a spill or release within the drinking water capture zone.

The hydrologic sensitivity is moderate for the well (Table 2, page 11). This rating may have been reduced even further if a well log for the Anderson Circle Water Corporation could have been located and implemented into the report. Well logs contain valuable information concerning each geologic

layer that the well driller passed through while constructing the well.

Well Construction

Well construction directly affects the ability of the well to protect the aquifer from contaminants. System construction scores are reduced when information shows that potential contaminants will have a more difficult time reaching the intake of the well. Lower scores imply a system is less vulnerable to contamination. For example, if the well casing and annular seal both extend into a low permeability unit, then the possibility of contamination is reduced and the system construction score goes down. If the highest production interval is more than 100 feet below the water table, then the system is considered to have a better buffering capacity. In addition, if the wellhead and surface seal are maintained to standards, as outlined in sanitary surveys, then contamination down the well bore is less probable. Also, if the wellhead is protected from surface flooding and is outside the 100-year floodplain, then the likelihood of contamination from surface events is reduced.

The well construction score for the Anderson Circle Water Corporation was moderate. Because an applicable well log for the system was unavailable, the intricacies of the well's casing, production intervals, and annular seal are not known. Therefore, the moderate ranking is somewhat conservative. However, according to the 2000 Sanitary Survey conducted by the Central District Health Department, the well seal is in compliance and should provide an initial barrier to precipitation and other surface events. This data, in turn, slightly reduced the well construction score.

Potential Contaminant Source and Land Use

The well rated moderate for IOCs (i.e. nitrates, arsenic), VOCs (i.e. petroleum products), and SOC (i.e. pesticides), and low for microbial contaminants (i.e. bacteria). These ratings can be attributed, in large part, to the presence of a potential contaminant source within a 50-foot radius of the well bore. This potential source is a seasonal irrigation ditch, which is situated approximately 30 feet from the Anderson Circle well. Because it is unknown whether the ditch is hydraulically connected to the well water, the overall susceptibility scores were increased. Without any potential sources of contamination in this 50-foot radius circle, the well would have rated a moderate overall susceptibility to all classes of pollutants.

The predominant land use within the designated drinking water capture zone is urban/commercial. These areas may be vulnerable to ground water contamination due to urban runoff during storm events, improper disposal of household hazardous wastes, and industrial pollutants, to name just a few.

There are numerous potential sources of contamination within the delineated drinking water capture zone. These sources can be found in Table 1 (pages 20-21), along with the class of contaminants stored at each site. In addition, the 1995 Ground Water Under Direct Influence (GWUDI) field survey conducted by the Central District Health Department indicates the presence of a sewer line, which is situated about 50 feet from the well bore. For the purposes of the susceptibility analysis, this sewer line was considered a possible source of IOC and microbial pollution.

Furthermore, Federal Way and Broadway Avenue pass directly through Zone 1B. Because both of these roads serve as important transportation thoroughfares for the region, they were incorporated into the analysis as possible origins for pollutants.

A known VOC plume also intercepts the edge of the 10-year TOT zone. The Anderson Circle Water Corporation may want to periodically monitor for VOCs, since they are known to be in the groundwater immediately up-gradient from the well.

Final Susceptibility Ranking

A detection above a drinking water standard MCL, any detection of a VOC or SOC, or a repeat detection of total coliform bacteria or fecal coliform bacteria at the wellhead will automatically give a high susceptibility rating to a well despite the land use of the area because a pathway for contamination already exists. Additionally, potential contaminant sources within 50 feet of a wellhead will lead to an automatically high susceptibility rating. Hydrologic sensitivity and system construction scores are heavily weighted in the final scores. Having multiple potential contaminant sources in the 0- to 3-year time of travel zone (Zone 1B) and the presence of agricultural land contribute greatly to the overall ranking.

The Anderson Circle Water Corporation water system could have rated a lower overall susceptibility if Zone 1A was free of any potential sources of pollutants. Furthermore, the addition of data included in an applicable well log may have further lowered the overall susceptibility scores. Instead, the system rated a high overall susceptibility to all classes of contaminants (Table 2).

Table 2. Summary of the Anderson Circle Water Corporation Susceptibility Evaluation

Table 2: Summary of the Anderson Creek Water Quality Assessment										
Well	Susceptibility Scores ¹									
	Hydrologic Sensitivity	Contaminant Inventory				System Construction	Final Susceptibility Ranking			
		IOC	VOC	SOC	Microbials		IOC	VOC	SOC	Microbials
Well #1	M	M	M	M	L	M	H*	H*	H*	H*

¹H = High Susceptibility, M = Moderate Susceptibility, L = Low Susceptibility,

IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

H* = Well automatically rated a high susceptibility ranking due to the presence of an irrigation ditch within Zone 1A.

Susceptibility Summary

A moderate hydrologic sensitivity and moderate system construction combined to give the well a high overall rating for all contaminants. These high ratings can be attributed to the presence of an irrigation ditch within 30 feet of the well bore. Because it is unknown whether the water in this ditch is hydraulically connected to the well, the susceptibility scores were increased. Though there have been no significant water chemistry problems in the ground water, there have been detections of total coliform bacteria in routine water samples collected from the system. No VOCs or SOCs have ever been detected in the well water. However, the delineated source water area does reside in an area of urban and commercial land uses. These areas may be vulnerable to ground water contamination due to urban runoff during storm events, improper disposal of household hazardous wastes, and industrial pollutants, to name just a few.

Section 5. Options for Drinking Water Protection

The susceptibility assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what the susceptibility ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

An effective drinking water protection program is tailored to the particular local source water protection area. A community with a fully developed drinking water protection program will incorporate many strategies. For the Anderson Circle Water Corporation, drinking water protection activities should first focus on continued maintenance of the sanitary seal and distribution system. Actions should also be taken to keep a 50-foot radius circle clear around the wellhead. Because the aforementioned irrigation ditch passes through this zone, the system may want to investigate practices that could minimize its impact on the drinking water supply. Additionally, any spills occurring on either Federal Way or Broadway Avenue should be monitored and dealt with expeditiously.

Because a portion of the ground water capture zone is outside the direct jurisdiction of the Anderson Circle Water Corporation, the creation of partnerships with state and local agencies and industry groups are critical to the success of drinking water protection. The water system may want to cooperate with the businesses in Table 1 (pages 20-21) to encourage the use of pollution prevention methods and specific best management practices (BMPs). Should microbial contamination become a continuing problem, appropriate disinfection practices would need to be implemented to ensure the health of the Anderson Circle Water Corporation residents.

Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term. A strong public education program should be a primary focus of any drinking water protection plan, especially since the delineation contains some urban and residential land uses. Public education topics could include proper lawn care practices, household hazardous waste disposal methods, and the importance of water conservation to name but a few.

There are multiple resources available to help communities implement protection programs, including the Drinking Water Academy of the U.S. Environmental Protection Agency. In addition, because two major transportation corridors (Federal Way and Broadway Avenue) pass through the delineation, the Idaho Department of Transportation should be involved in any protection measures. Drinking water protection practices dealing with agriculture should be coordinated with the Idaho State Department of Agriculture, the Soil Conservation Commission, the Ada County Soil Conservation District, and the Natural Resources Conservation Service.

A community must incorporate a variety of strategies in order to develop a comprehensive drinking water protection plan, be they regulatory in nature (i.e. zoning, permitting) or non-regulatory in nature (i.e. good housekeeping, public education, specific best management practices). For assistance in developing protection strategies please contact the Boise Regional Office of the Idaho Department of Environmental Quality or the Idaho Rural Water Association.

Assistance

Public water supplies and others may call the following DEQ offices with questions about this assessment and to request assistance with developing and implementing a local protection plan. In addition, draft protection plans may be submitted to the DEQ office for preliminary review and comments.

Boise Regional DEQ Office (208) 373-0550

State DEQ Office (208) 373-0502

Website: <http://www2.state.id.us/deq>

Water suppliers serving fewer than 10,000 persons may contact John Bokor, Idaho Rural Water Association, at 1-800-962-3257 for assistance with wellhead protection strategies.

POTENTIAL CONTAMINANT INVENTORY LIST OF ACRONYMS AND DEFINITIONS

AST (Aboveground Storage Tanks) – Sites with aboveground storage tanks.

Business Mailing List – This list contains potential contaminant sites identified through a yellow pages database search of standard industry codes (SIC).

CERCLIS – This includes sites considered for listing under the **Comprehensive Environmental Response Compensation and Liability Act (CERCLA)**. CERCLA, more commonly known as **ASuperfund**, is designed to clean up hazardous waste sites that are on the national priority list (NPL).

Cyanide Site – DEQ permitted and known historical sites/facilities using cyanide.

Dairy – Sites included in the primary contaminant source inventory represent those facilities regulated by Idaho State Department of Agriculture (ISDA) and may range from a few head to several thousand head of milking cows.

Deep Injection Well – Injection wells regulated under the Idaho Department of Water Resources generally for the disposal of stormwater runoff or agricultural field drainage.

Enhanced Inventory – Enhanced inventory locations are potential contaminant source sites added by the water system. These can include new sites not captured during the primary contaminant inventory, or corrected locations for sites not properly located during the primary contaminant inventory. Enhanced inventory sites can also include miscellaneous sites added by the Idaho Department of Environmental Quality (DEQ) during the primary contaminant inventory.

Floodplain – This is a coverage of the 100year floodplains.

Group 1 Sites – These are sites that show elevated levels of contaminants and are not within the priority one areas.

Inorganic Priority Area – Priority one areas where greater than 25% of the wells/springs show constituents higher than primary standards or other health standards.

Landfill – Areas of open and closed municipal and non-municipal landfills.

LUST (Leaking Underground Storage Tank) – Potential contaminant source sites associated with leaking underground storage tanks as regulated under RCRA.

Mines and Quarries – Mines and quarries permitted through the Idaho Department of Lands.)

Nitrate Priority Area – Area where greater than 25% of wells/springs show nitrate values above 5mg/l.

NPDES (National Pollutant Discharge Elimination System) – Sites with NPDES permits. The Clean Water Act requires that any discharge of a pollutant to waters of the United States from a point source must be authorized by an NPDES permit.

Organic Priority Areas – These are any areas where greater than 25 % of wells/springs show levels greater than 1% of the primary standard or other health standards.

Recharge Point – This includes active, proposed, and possible recharge sites on the Snake River Plain.

RICRIS – Site regulated under **Resource Conservation Recovery Act (RCRA)**. RCRA is commonly associated with the cradle to grave management approach for generation, storage, and disposal of hazardous wastes.

SARA Tier II (Superfund Amendments and Reauthorization Act Tier II Facilities) – These sites store certain types and amounts of hazardous materials and must be identified under the Community Right to Know Act.

Toxic Release Inventory (TRI) – The toxic release inventory list was developed as part of the Emergency Planning and Community Right to Know (Community Right to Know) Act passed in 1986. The Community Right to Know Act requires the reporting of any release of a chemical found on the TRI list.

UST (Underground Storage Tank) – Potential contaminant source sites associated with underground storage tanks regulated as regulated under RCRA.

Wastewater Land Applications Sites – These are areas where the land application of municipal or industrial wastewater is permitted by DEQ.

Wellheads – These are drinking water well locations regulated under the Safe Drinking Water Act. They are not treated as potential contaminant sources.

NOTE: Many of the potential contaminant sources were located using a geocoding program where mailing addresses are used to locate a facility. Field verification of potential contaminant sources is an important element of an enhanced inventory.

Where possible, a list of potential contaminant sites unable to be located with geocoding will be provided to water systems to determine if the potential contaminant sources are located within the source water assessment area.

References Cited

- Anderson, J.E. and Wood, S.H., 1981. Geological, Hydrological Geochemical and Geophysical Investigations of the Nampa-Caldwell and Adjacent Areas, Southwestern Idaho. Chapter 3, Geohydrology, In: Mitchell, J. C., ed., Geothermal Investigations in Idaho, Part 11: Idaho Department of Water Resources, Water Information Bulletin 30: p. 33-42.
- Central District Health Department, 1995. Ground water Under Direct Influence (GWUDI) Field Survey Report.
- Central District Health Department, 2000. Sanitary Survey Report for the Anderson Circle Water Corporation.
- Clemens, D.M., 1993. Volcanic stratigraphy and tectonic development, Western Snake River Plain, Idaho. M.S. Thesis, Arizona State University.
- Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, 1997. "Recommended Standards for Water Works."
- Idaho Department of Agriculture, 1998. Unpublished Data.
- Idaho Department of Environmental Quality, 1997. Design Standards for Public Drinking Water Systems. IDAPA 58.01.08.550.01.
- Idaho Department of Water Resources, 1993. Administrative Rules of the Idaho Water Resource Board: Well Construction Standards Rules. IDAPA 37.03.09.
- Malde, H.E., 1991. Quaternary geology and structural history of the Snake River Plain, Idaho and Oregon. In: The Geology of North America, Quaternary Nonglacial Geology: Conterminous U.S., Vol. K-2, 252-281 pp.
- Malde, H.E. and Powers, H.A., 1962. Upper Cenozoic stratigraphy of Western Snake River Plain. Geological Society of America Bulletin, 73: 1197-1220.
- Neely, K.W. and J.K. Crockett, 1998. "Ground Water Quality Characterization and Initial Trend Analyses for the Treasure Valley Shallow and Deep Hydrogeologic Subareas," Idaho Department of Water Resources, Water Information Bulletin No. 50, Part 3.
- Othberg, K.L., 1994. Geology and geomorphology of the Boise Valley and adjoining areas, western Snake River Plain, Idaho. Idaho Geological Survey Bulletin 29: 54 pp.
- Othberg, K.L. and Stanford, L., 1992. Geologic map of the Boise Valley and adjoining area, Western Snake River Plain, Idaho. Idaho Geological Survey.
- Petrich, C.R. and S.M. Urban, 1996. "Treasure Valley Hydrologic Project Background – Draft," September, 1996.

- Petrich, C.R. and J.H. Hutchings (IWRR), S.M. Urban and R.A. Carlson (IDWR), 1999. "Progress Report on the Characterization of Treasure Valley Ground Water Resources – Draft," prepared for and in cooperation with the Idaho Department of Water Resources, June 30, 1999.
- Squires, E., Wood, S.H. and Osiensky, J.L., 1992. Hydrogeologic Framework of the Boise Aquifer System, Ada County, Idaho, Research Technical Completion Report, Idaho Water Resources Research Institute, University of Idaho. 114 pp.
- Wood, S.H., 1994. Seismic expression and geological significance of a lacustrine delta in Neogene deposits of the Western Snake River Plain, Idaho. AAPG Bulletin, 1(January): p. 102-121.
- Wood, S.H. and Anderson, J.E., 1981. Part 11: Geological, hydrological, and geochemical and Geophysical investigations of the Nampa-Caldwell and adjacent areas, southwestern Idaho. In: J.C. Mitchell (Editor), Geothermal investigations in Idaho. Idaho Department of Water Resources.
- Wuolo, R.W., J. Wittman, and D.M. Reynolds, 2001. "Summary Report: Delineation of Public Drinking Water Sources for the Source Water Assessment Program: Boise Valley and Mountain Home Plateau," BARR, Minneapolis, August 2001.

Attachment A

Delineation Figures and Potential Contaminant Source Table for Anderson Circle Water Corporation

FIGURE 1: Geographic Location of the Anderson Circle Water Corp.





FIGURE 2 - Anderson Circle Water Corp. Delineation Map and Potential Contaminant Source Locations



0 0.5 1 Miles

LEGEND			
Time of Travel Zones	⊙ Business Mailing List	● Recharge Point	
1B (3 yr TOT)	★ Dairy	● SARA Title III Site (EPCRA)	
2 (6 yr TOT)	● LUST Site	● Injection Well	
3 (10 yr TOT)	● NPDES Site	● Group I Site	
● Wellhead	⚡ Mine	● Cyanide Site	
+ Enhanced Inventory	⊙ AST	Landfill	
Toxic Release Inventory	UST Site	Wastewater Land App. Site	
⊙ CERCLIS Site	▲ Closed		
● RICIS Site	▲ Open		



PWS# 4010005
WELL# 1

Table 1. Anderson Circle Water Corporation Potential Contaminant Inventory

SITE #	Source Description ¹	TOT Zone ² (years)	Source of Information	Potential Contaminants ³
	Federal Way	0-3	GIS Map	IOC, VOC, SOC, Microbes
	Broadway Avenue	0-3	GIS Map	IOC, VOC, SOC, Microbes
	Irrigation Ditch	0-3	CDHD 1995 GWUDI	IOC, VOC, SOC, Microbes
	City Sewer Line	0-3	CDHD 1995 GWUDI	IOC, VOC, SOC, Microbes
1	Glass Coating and Tinting	0-3	Business Mailing List	IOC, VOC
2,11	RCRIS Site-Food Processors	0-3	Database Search	IOC, VOC, SOC
3	Tire Dealers & Automobile Service	0-3	Business Mailing List	IOC, VOC, SOC
4	Contractor-Heavy Equipment & Supplies	0-3	Business Mailing List	IOC, VOC, SOC
5	Floor Refinishing & Resurfacing	0-3	Business Mailing List	IOC, VOC, SOC
6	Rescue Squad	0-3	Business Mailing List	VOC, SOC
7	Excavating Contractor	0-3	Business Mailing List	IOC, VOC, SOC
8	Photo Processing & Finishing	0-3	Business Mailing List	IOC, VOC
9	Storage-Household & Commercial	0-3	Business Mailing List	IOC, VOC, SOC
10	Roofing Contractor	0-3	Business Mailing List	IOC, VOC, SOC
12,13	SARA Site/RCRIS Site-Electron Tube Manufacturer	0-3	Database Search	IOC, VOC, SOC
14,20	LUST/UST Site-Gas Station	3-6	Database Search	VOC, SOC
15,25,43	UST/RCRIS Site-Diesel Engines Wholesale	3-6	Database Search	IOC, VOC, SOC
16	UST-Local Government	3-6	Database Search	VOC, SOC
17,26,39	UST Site-Automobile Repair & Service	3-6	Business Mailing List	IOC, VOC, SOC
18,31,47,50	AST/UST/SARA Site-Lubricating Oils Wholesale	3-6	Database Search	IOC, VOC, SOC
19,29	UST-Gas Station	3-6	Business Mailing List	IOC, VOC, SOC
21	Storage-Houschold & Commercial	3-6	Business Mailing List	IOC, VOC, SOC
22	Tire Store-Automobile Repair & Service	3-6	Business Mailing List	IOC, VOC, SOC
23	Automobile Lubrication Service	3-6	Business Mailing List	IOC, VOC, SOC
24,38	Veterinarian Clinic	3-6	Business Mailing List	IOC, SOC
27	Storage-Household & Commercial	3-6	Business Mailing List	IOC, VOC, SOC
28	Lawn Mowers & Equipment	3-6	Business Mailing List	IOC, VOC, SOC
30	Rental Service-Stores & Yards	3-6	Business Mailing List	IOC, VOC, SOC
32,48	SARA Site-Heavy Equipment Rental	3-6	Database Search	IOC, VOC, SOC
33	Mufflers-Auto repair & Service	3-6	Business Mailing List	IOC, VOC, SOC
34,35	Microfilming Service & Equipment	3-6	Business Mailing List	IOC, VOC, SOC
36	Janitorial Service	3-6	Business Mailing List	IOC, VOC, SOC
37	Lawn Maintenance	3-6	Business Mailing List	IOC, SOC
40	Automobile Lubrication Service	3-6	Business Mailing List	IOC, VOC, SOC
41	Window Cleaning	3-6	Business Mailing List	IOC, VOC, SOC
42	Lawn & Garden Equipment & Supplies	3-6	Business Mailing List	IOC, SOC
44	RCRIS Site-Auto Paint Shop	3-6	Database Search	IOC, VOC, SOC
45	RCRIS Site-Transport Company	3-6	Database Search	IOC, VOC, SOC

46	RCRIS Site-Automotive Electric	3-6	Database Search	IOC, VOC, SOC
49	SARA Site-Gas Station	3-6	Database Search	IOC, VOC, SOC
51,52,59,60	LUST/UST/RCRIS Site-Dairy Farm	6-10	Database Search	IOC
53	Portrait Photographers	6-10	Business Mailing List	IOC, VOC
54	Metal Building Construction	6-10	Business Mailing List	IOC, VOC, SOC
55	Hardware-Retail	6-10	Business Mailing List	IOC, VOC, SOC
56	Filters-Liquid Manufacturers	6-10	Business Mailing List	IOC, VOC, SOC
57	Floor Refinishing 7 Resurfacing	6-10	Business Mailing List	IOC, VOC, SOC
58	Newspaper Publisher	6-10	Business Mailing List	IOC, VOC

¹ Find Source Description definitions on page 15

² TOT = time-of-travel (in years) for a potential contaminant to reach the wellhead

³ IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

NOTE: The site number in this table corresponds to Figure 2, page 19.

Attachment B

Anderson Circle Water Corporation Susceptibility Analysis Worksheet

The final scores for the susceptibility analysis were determined using the following formulas:

- 1) VOC/SOC/IOC Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.2)
- 2) 2) Microbial Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.375)

Final Susceptibility Scoring:

0 - 5 Low Susceptibility

6 - 12 Moderate Susceptibility

≥ 13 High Susceptibility

Ground Water Susceptibility Report

Public Water System Name : ANDERSON CIRCLE WATER CORP
Public Water System Number 4010005

Well# : WELL #1
1/2/02 12:43:19 PM

1. System Construction		SCORE			
Drill Date	circa 1946				
Driller Log Available	NO				
Sanitary Survey (if yes, indicate date of last survey)	YES	2000			
Well meets IDWR construction standards	NO	1			
Wellhead and surface seal maintained	YES	0			
Casing and annular seal extend to low permeability unit	NO	2			
Highest production 100 feet below static water level	NO	1			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		4			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	YES	0			
Vadose zone composed of gravel, fractured rock or unknown	YES	1			
Depth to first water > 300 feet	NO	1			
Aquitard present with > 50 feet cumulative thickness	NO	2			
Total Hydrologic Score		4			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	URBAN/COMMERCIAL	2	2	2	2
Farm chemical use high	NO	0	0	0	
IOC, VOC, SOC, or Microbial sources in Zone 1A	YES	YES	YES	YES	YES
Total Potential Contaminant Source/Land Use Score - Zone 1A		2	2	2	2
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	YES	13	130	100	4
(Score = # Sources X 2) 8 Points Maximum		8	8	8	8
Sources of Class II or III leacheable contaminants or	YES	5	8	2	
4 Points Maximum		4	4	2	
Zone 1B contains or intercepts a Group 1 Area	NO	0	0	0	0
Land use Zone 1B	Less Than 25% Agricultural Land	0	0	0	0
Total Potential Contaminant Source / Land Use Score - Zone 1B		12	12	10	8
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	YES	2	2	2	
Sources of Class II or III leacheable contaminants or	YES	1	1	1	
Land Use Zone II	Less than 25% Agricultural Land	0	0	0	
Potential Contaminant Source / Land Use Score - Zone II		3	3	3	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	YES	1	1	1	
Sources of Class II or III leacheable contaminants or	YES	1	1	1	
Is there irrigated agricultural lands that occupy > 50% of	NO	0	0	0	
Total Potential Contaminant Source / Land Use Score - Zone III		2	2	2	0
Cumulative Potential Contaminant / Land Use Score		19	19	17	10
4. Final Susceptibility Source Score		12	12	11	12
5. Final Well Ranking		High	High	High	High